

**Capital Region Water (CRW):** On September 24, 2020, EPA met virtually with CRW and PADEP to discuss the technical issues in the collection system and proposed CSO projects for the next 10-years. The LTCP, originally due April 1, 2018, has not yet been approved despite lengthy discussions and analyses during meetings and conference calls with the parties. CRW is alleging that after 30 years of neglect its wastewater system was so dilapidated that it will take them 47-years to meet the CSO presumptive approach of 85% capture. The goal of the case team is to focus on remedial projects that they can accomplish in the first 10-years. Overall, the 10-year plan was encouraging.

**Ex. 5 Deliberative Process (DP)**

**Ex. 5 Deliberative Process (DP)** The next call with CRW is scheduled for October 13, 2020 and will primarily focus on follow-up technical concerns with the H&H model, the rehabilitation of the Front Street Interceptor, and CRWs green/gray approach.

The Case team is developing work items to be incorporated into an amended Partial Consent Decree (PCD)

**Ex. 5 Deliberative Process (DP)**

projects and several proposed CSO projects that will bring the CRW combined collection system

**Ex. 5 Deliberative Process (DP)** and still retain the requirement to concurrently develop an approvable LTCP that will allow CRW to implement an adaptive management approach.